



Paul PCS - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Paul PCS	WS-032-001	Cooler	3	In hallway adjacent to stairway 8 on north side			WF-072019-032001-02	11/15/2019	FT-FY20-072019-032001-A	<1	FT-FY20-072019-032001-B	<1
Paul PCS	WS-032-002	Cooler	3	In hallway adjacent to room 305			WF-072019-032002-02	11/15/2019	FT-FY20-072019-032002-A	<1	FT-FY20-072019-032002-B	<1
Paul PCS	WS-032-003	Cooler	3	In hallway adjacent to room 309			WF-072019-032003-02	11/15/2019	FT-FY20-072019-032003-A	<1	FT-FY20-072019-032003-B	<1
Paul PCS	WS-032-004	Break Room	3	In break room S302			WF-072019-032004-02	11/15/2019	FT-FY20-072019-032004-A	<1	FT-FY20-072019-032004-B	<1
Paul PCS	WS-032-005	Cooler	2	In hallway adjacent to room S204			WF-072019-032005-02	11/15/2019	FT-FY20-072019-032005-A	<1	FT-FY20-072019-032005-B	<1
Paul PCS	WS-032-006	Cooler	2	In hallway adjacent to room 210			WF-072019-032006-02	11/15/2019	FT-FY20-072019-032006-A	<1	FT-FY20-072019-032006-B	<1
Paul PCS	WS-032-007	Cooler	2	In hallway adjacent to room 206			WF-072019-032007-02	11/15/2019	FT-FY20-072019-032007-A	<1	FT-FY20-072019-032007-B	<1
Paul PCS	WS-032-008	Cooler	2	In hallway adjacent to room N201			WF-072019-032008-02	11/15/2019	FT-FY20-072019-032008-A	<1	FT-FY20-072019-032008-B	<1
Paul PCS	WS-032-009	Cooler	1	In hallway adjacent to room N104			WF-072019-032009-02	11/15/2019	FT-FY20-072019-032009-A	<1	FT-FY20-072019-032009-B	<1
Paul PCS	WS-032-010	Break Room	1	In staff lounge N107			WF-072019-032010-02	11/15/2019	FT-FY20-072019-032010-A	<1	FT-FY20-072019-032010-B	<1
Paul PCS	WS-032-011	Cooler	1	In hallway adjacent to room 105			WF-072019-032011-02	11/15/2019	FT-FY20-072019-032011-A	<1	FT-FY20-072019-032011-B	<1
Paul PCS	WS-032-012	Cooler	1	In hallway adjacent to room 108			WF-072019-032012-02	11/15/2019	FT-FY20-072019-032012-A	<1	FT-FY20-072019-032012-B	<1
Paul PCS	WS-032-013	Cooler	1	In hallway adjacent to room S104			WF-072019-032013-02	11/15/2019	FT-FY20-072019-032013-A	<1	FT-FY20-072019-032013-B	<1
Paul PCS	WS-032-014	Cooler	Basement	In cafeteria north side			WF-072019-032014-02	11/15/2019	FT-FY20-072019-032014-A	<1	FT-FY20-072019-032014-B	<1
Paul PCS	WS-032-015	Food Prep Sink	Basement	In kitchen 1st sink clockwise from door		Left	WF-072019-032015-02	11/15/2019	FT-FY20-072019-032015-A	<1	FT-FY20-072019-032015-B	<1
Paul PCS	WS-032-016	Food Prep Sink	Basement	In kitchen 2nd sink clockwise from door		Right	WF-072019-032016-02	11/15/2019	FT-FY20-072019-032016-A	<1	FT-FY20-072019-032016-B	<1
Paul PCS	WS-032-017	Cooler	Basement	In cafeteria south side			WF-072019-032017-02	11/15/2019	FT-FY20-072019-032017-A	<1	FT-FY20-072019-032017-B	<1
Paul PCS	WS-032-018	Cooler	2	In hallway across from room 208 in new building	High	Left	WF-072019-032018-02	11/15/2019	FT-FY20-072019-032018-A	<1	FT-FY20-072019-032018-B	<1
Paul PCS	WS-032-019	Cooler	2	In hallway across from room 208 in new building	Low	Right	WF-072019-032019-02	11/15/2019	FT-FY20-072019-032019-A	<1	FT-FY20-072019-032019-B	<1
Paul PCS	WS-032-020	Cooler	1	In hallway across from room 109 in new building	High	Left	WF-072019-032020-02	11/15/2019	FT-FY20-072019-032020-A	<1	FT-FY20-072019-032020-B	<1
Paul PCS	WS-032-021	Cooler	1	In hallway across from room 109 in new building	Low	Right	WF-072019-032021-02	11/15/2019	FT-FY20-072019-032021-A	<1	FT-FY20-072019-032021-B	<1
Paul PCS	WS-032-022	Ice Maker	Basement	In kitchen			WF-072019-032022-02	11/15/2019	FT-FY20-072019-032022-A	<1	FT-FY20-072019-032022-B	<1
Paul PCS	WS-032-023	Bottle Filler	1	In hallway adjacent to room 108	High		WF-072019-032023-02	11/15/2019	FT-FY20-072019-032023-A	<1	FT-FY20-072019-032023-B	<1